



CERTIFIED SOLAR THERMAL SYSTEM

SUPPLIER:
Alternate Energy Technologies
 1345 Energy Cove Court
 Green Cove Springs, FL 32043 USA
 www.aetsolar.com

MODEL: DXP-120-64
 THERMAL SYSTEM TYPE: Pumped, Indirect
 CERTIFICATION #: S00165B
 Original Certification: September 01, 2009
 Expiration Date: September 01, 2029

This system was evaluated by the Florida Solar Energy Center (FSEC) in accordance with the Florida Standards Program for Solar Domestic Water and Pool Heating Systems (FSEC Standard 104-10) and was found to meet the minimum standards established by FSEC.

The calculated Florida Energy Factors (FEF) for this system are:		
FEF North (FEF _N)	FEF Central (FEF _C)	FEF South (FEF _S)
4.10	6.10	6.70

Option	Collector Panel Manufacturer	Collector Panel Certification Number	Collector Panel Model Number	Quantity	Total Panel area	Total Panel area
1	Alternate Energy Technologies	00089N	AE-32	2	5.93 (m ²)	63.82 (ft ²)

Tank Manufacturer	Model	Capacity	Type	Equivalent Tank may be substituted
American	SE 62-119H-045S	454 liter	Solar	YES

Pump Manufacturer	Model Number	Power Draw	Type
Grundfos	UPS 15/68	75 W	Centrifugal
TACO	009-F5	160 W	Centrifugal

Controller Manufacturer	Model Number	Type
Goldline Controls	GL-30-LCO	Differential
AEE Solar, Inc.	AE-10ST	PV

Freeze Protection 1: Drainback
Freeze Protection 2:

REMARKS:

Joseph Walters
 Technical Director



Missing System Diagram Image

If you need System diagram image please contact FSEC
at thermal@fsec.ucf.edu.

